

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0948:101 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: World Electronics, 12233 NW 35th St., Coral Springs FL 33065
Contact: Phillip Barrett (888) 625-7533*

DESIGN: Model 510 transmitter; Models WRM-1, TC-2, YA and OM repeaters; and Model IR isolation relay. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as signaling devices and transmitter for use with Model 2085B control unit (CSFM Listing No. 7165-0948:102). The wiring between the Model 510 transmitter and the initiating device must be within the same room.

*Rev. 06-04-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 4, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager